



**BASCO®/WHITLOCK®
INSTALLATION &
MAINTENANCE
GUIDE**



API Heat Transfer

...world leaders in heat transfer technology

INSTALLATION AND OPERATIONAL PROCEDURES FOR BASCO/WHITLOCK HEAT EXCHANGERS

INSTALLATION

SITE SELECTION is the first step to insure proper installation of Basco/Whitlock heat transfer equipment. It is important that the heat exchanger is easily accessible for inspection, maintenance and cleaning.

(AEW)

Straight Tube heat exchangers (removable bundles)-allow for sufficient clearance at the stationary head end for removal of the bundle from the shell and provide adequate space beyond the rear head to accommodate removal of the shell cover and/or floating head cover.

Fixed Tubesheet heat exchangers-provide sufficient clearance at one end for withdrawal and replacement of the tubes and enough space beyond the head at the opposite end to permit removal of the bonnet or channel cover.

U-Tube heat exchangers-provide sufficient clearance at the stationary head end for withdrawal of the tube bundle, or at the opposite end to permit the removal of the shell.

FOUNDATIONS must be sufficiently heavy as to provide permanent support without settling, and to absorb any normal vibrations from outside causes.

Most Basco/Whitlock heat exchangers are equipped with cradles for horizontal installation, or brackets for vertical installation. If the supports are integral, the foundation bolts at the end opposing the channel should be loosened to allow free expansion and contraction of the shell.

The exchanger should be set level and square so pipe connections can be made without forcing to reduce the possibility of leaks during operation.

INSPECT all exchanger openings for foreign material before installation. The entire system should be clean before starting operation. Do not remove protective plugs and covers until just prior to installation.

Pieces of gaskets, metal chips, scale and similar materials can plug tubes. To minimize the risk of blockage, take the following precautions:

- Use care in placing gaskets.
- Do not use valves with soft seats.
- Blow-out pipelines before connecting to the unit.


FITTINGS AND PIPING are critical in the proper installation of API Heat Transfer equipment. To insure the full rated capacity of the unit it is important to select the proper pipe sizes. While pipe connections for average conditions are specified on certified drawings, further thought must be given to plant conditions – such as length of pipes, fittings, obstructions, and the allowable pressure drop through the heat exchanger.

By-Pass Valves should be provided in both circuits of the unit to permit periodic inspection or repair without interruption of the fluid flow.


Test Connections for thermometer well and pressure gauges should be installed close to the exchanger in the inlet and outlet piping, when not integral with the exchanger nozzles.

Inert Gas Vents should be provided to prevent gas binding of the heat transfer surface and a subsequent reduction in thermal capacity in condensing units.


STRAIGHT TUBE



FIXED TUBESHEET



U-TUBE



WARNING: DRESS SAFELY.

Make a list of all protective clothing and/or safety equipment recommended by the manufacturers of all items or equipment used in the installation. Follow all the safety practices and procedures outlined by each respective manufacturer.

INSTALLATION AND OPERATIONAL PROCEDURES FOR BASCO/WHITLOCK HEAT EXCHANGERS

Drain Piping must be suitable for discharge to the atmosphere (if permissible), or into a vessel at lower pressure. Do not pipe to a common closed manifold.

Fluid Pulsations and Mechanical Vibrations to heat exchangers must be minimized in all installations. Install surge drums when the liquid is being delivered to the unit by a reciprocating pump, as the vibration can cause serious damage to the tubes.

Gage Glasses in condensing units should be installed to show liquid level.


Safety Device Connections are provided when required on shells. To safeguard against failures or possible ruptures during operation, the unit must be protected with a safety relief valve or rupture disk of an approved type and make, set at the proper pressure. In the tube circuit, such devices should be placed in the inlet piping between the nearest valve and the unit.

EXTERNAL BOLTED JOINTS may require re-tightening in a uniform, diametrically staggered pattern, as illustrated below. Although all API heat transfer equipment is pressure tested before leaving our plants, normal relaxing of the gasketed joints may occur in the interval between testing and start-up.

Torque Values for Compressed Fiber Gaskets*

SIZE	TORQUE (FT. LBS.)	TORQUE STEPS
1/4-20	8	1
5/16-18	16	1
3/8-16	24	2
1/2-13	60	2
5/8-11	120	2
3/4-10	200	3
1-8	490	3
1 1/8-8	710	3
1 1/4-8	1000	3
1 1/2-8	1600	3
1 3/4-8	3000	4
2-8	4400	4

*Contact factory for other types of gaskets. (See drawings or parts list for gasket information.)



BOLT TIGHTENING PROCEDURE

OPERATION

Operation Procedures must be strictly followed in start-up and shut-down sequences, especially in fixed tubesheet units where improper start-up or shut-down may cause leaking of tube-to-tubesheet and/or bolted flanged joints. Heat exchangers should not be subjected to abrupt temperature fluctuations. Hot fluid must not be introduced when the unit is cold, nor cold fluid introduced when the unit is hot.

Equipment must not be operated at conditions which exceed those for which the unit was designed.

CAUTION: Heat exchangers are pressure vessels. The stated operational pressures and temperatures should NOT be exceeded.

START-UP

1. Check system for cleanliness to avoid plugging of tubes and pass partitions with refuse. Protective screens or strainers in piping to the heat exchanger are recommended.
2. Vent valves should be opened before fluid is admitted to heat exchanger.
3. Check all flange bolting for tightness.
4. Start flow of fluids gradually, introducing colder fluid first. When system is completely filled and all air vented, close vent valves.
5. When operating temperatures are reached, bolting and packed joints should be retightened to prevent leaks and gasket failures.
6. The heat exchanger should never be operated at pressures, temperatures and flows in excess of those specified on the nameplate and design specification sheet.
7. For heat exchangers used in steam service, provision must be made to drain accumulated condensate prior to start-up.

THERMAL SHOCK

Extreme caution must be taken to avoid subjecting the heat exchanger to thermal shock, excessive pressures and temperatures. These conditions can impose stresses resulting in premature heat exchanger failure as well as other components in the system.

SHUT-DOWN

Most heat exchangers with removable tube bundles may be shut-down by gradually reducing the flow of the hot medium and then the cold medium. Should it be necessary to stop the cold fluid first then the hot medium should be stopped at once. For a fixed bundle heat exchanger, both mediums should be stopped in such a manner to minimize the differential thermal expansion between shell and tubes. By-pass piping may be incorporated for this purpose.

INSTALLATION AND OPERATIONAL PROCEDURES FOR BASCO/WHITLOCK HEAT EXCHANGERS

MAINTENANCE

Typically, the failure of a heat exchanger to perform to specifications may be caused by one or more of the following factors: (1) excessive fouling, (2) air or gas binding resulting from improper piping installation or lack of suitable vents, (3) operating conditions differing from design conditions, (4) maldistribution of flow in the unit, and (5) excessive clearances between the baffles and shell and/or tubes due to corrosion.

Inspection of API Heat Transfer equipment at regular intervals, as frequently as experience indicates, can identify potential problems before any structural damage occurs. The inspection should include an examination of both the interior and exterior of the unit.

Failure to keep all tubes clean can result in severe flow restrictions through some tubes which could cause damaging thermal stresses, resulting in leaking tube joints or structural damage to other components.

Temperatures and pressures of the fluid entering and leaving the equipment should be checked regularly to evaluate the function of the unit. For example, an increase in the pressure drop across the unit – with an accompanying decrease in the temperature range may indicate vapor or gas binding.

A slight sludge or scale coating on the tube greatly reduces the heat transfer efficiency. Therefore, exchangers subject to fouling or scaling should be cleaned periodically. A marked increase in pressure drop and/or reduction in performance usually indicates cleaning is necessary. The unit should first be checked for air or vapor entrapment to confirm that this is not the cause for the reduction in performance. Since the difficulty of cleaning increases rapidly as the scale thickness or deposit increases, the intervals between cleanings should not be excessive.

Disassembly and removal of the bundle for visual inspection and cleaning is desirable. The bundle must be checked for excessive corrosion. Regular inspection and cleaning are highly recommended when the fluids handled are fouling, or highly corrosive.

CAUTION!: Before disassembly, the user must ensure that the unit has been completely shut down and depressurized, vented, drained, and neutralized and/or purged of hazardous material.

Care must be taken when “handling” the fouling material and the cleaning agent. Follow the chemical’s “handling instructions” and wear all forms of eye, respiratory and body protection recommended.

TUBE JOINT LEAKS can be located with the following procedures:

Fixed Tubesheet Exchangers – remove the channel covers and apply pressure on the shell side.

Floating Tubesheet Exchangers – remove the front channel cover and apply pressure on the shell side. Any leaks between the tubes and the front tubesheet will be evident immediately. Should a major leak occur in the rear tubesheet, the fluid will shortly be seen running out the bottom row of tubes. Minor leaks may require the removal of the tube bundle and the application of a pressure test on individual tubes.

U-Tube Exchangers – remove the bonnet or channel cover and test from the shell side. Be sure that all bolted contact surfaces are secured with all bolts in place and properly tightened.

Removal of the tube bundle requires the joint be first broken with a chisel, being careful not to damage the gasket surface, and then pried out using a chisel or crowbar.

Where the resistance to remove the bundle is great, a pair of hydraulic jacks placed diametrically opposite on the periphery of the tubesheet may be employed.

To remove a straight tube/floating tubesheet bundle, either of the above methods may be used or one of the following:

- Cables straps or chains may be attached to eyebolts screwed into the tubesheet. (Fig. A)
- Cables may be threaded through several tubes (tube diameter permitting) and pulled. The cable must be passed over a wooden block at the tube ends to protect such tube ends from damage. (Fig. B)

The bundle should be supported on the tube baffles, supports or tubesheets to prevent damage to the tubes.

The gasket and packing contact surfaces should be protected.

INSTALLATION AND OPERATIONAL PROCEDURES FOR BASCO/WHITLOCK HEAT EXCHANGERS

Tube Expanding – a suitable tube expander can be used to seal a leaking tube joint; however, care should be taken to insure that tubes are not over expanded. Proper care should be taken to prevent expanding the tube beyond the backside of the tubesheet.

CAUTION!: When removing the tube bundle...

- Do not exceed stated load capacities of any piece of equipment or tools used.
- Wear and/or follow all recommended protective clothing and other safety practices.

Cleaning of Basco/Whitlock heat exchangers is important to assure the equipment provides satisfactory performance. Heat transfer equipment may be cleaned by either chemical or mechanical methods. The method selected must be the choice of the operator of the plant and will depend on the type of deposit and the facilities available in the plant. These are suggested methods:

Problem	Solution
Water-soluble deposits	Flush with warm water
Soft, water-insoluble deposits	Circulate hot wash oil or light distillate through the tube and shell at a high velocity, followed by thorough rinsing
Sludges or cokes	If neither of the methods described above produce satisfactory results, try chemical cleaning solutions such as Oakite
Hard scale*	Should the scale not yield to the treatments mentioned above, then a chemical analysis of the scale is advisable. Such an analysis may indicate that careful washing with a dilute mineral acid and inhibitor, followed by thorough washing, will provide the required results. A mechanical cleaner, preferably a wire brush, can advantageously be employed, but care should be taken to prevent the cutting or scoring of the tube wall.




FIG. A






FIG. B



Tube expanded

Welded tube



Double tube sheet design

CAUTION!: CLEANING PRECAUTIONS

- Be careful to avoid damaging the tubes when mechanically cleaning a tube bundle.
- Cleaning compounds must be compatible with the metallurgy of the exchanger.

DO NOT:


- Introduce steam into an individual tube, as this can cause differential expansion stresses, with possible leakage at the tube joints.
- Introduce air into units handling inflammable or volatile fluids.

WARNING!: Chemical disposal of the substances used in and to clean the heat exchangers are HAZARDOUS! Follow all local, state and federal ordinances in the removal and disposal of these substances.

INSTALLATION AND OPERATIONAL PROCEDURES FOR BASCO/WHITLOCK HEAT EXCHANGERS

Frequent cleaning is important to prevent excessive deposits* on the tubes, since these deposits may result in plugging the tubes. Resultant overheating may be followed by leakage of the expanded joints, or result in other damage, and in a reduction in thermal capacity.

*Scale buildup can be prevented with the use of the API Anti-Scaler. Contact your local API Heat Transfer Sales Representative or the factory for more information.



NOTE: When using a mechanical tube expander, set the depth control collar to assure at least 1/8" between the expansion roller end and the inside of the tubesheet.

RE-ROLLING LOOSE TUBE JOINT

Gaskets and gasket surfaces should be thoroughly cleaned and should be free of scratches and other defects. Gaskets should be properly positioned before attempting to retighten bolts. It is required that when a heat exchanger is dismantled for any cause, it be reassembled with new gaskets. This will tend to prevent future leaks and/or damage to the gasket seating surfaces of the heat exchanger. Composition gaskets become dried out and brittle so that they do not always provide an effective seal when reused. Metal or metal jacketed gaskets, when compressed initially, flow to match their contact surfaces. In so doing they are work hardened and, if reused, may provide an imperfect seal or result in deformation and damage to the gasket contact surfaces of the exchangers.

Bolted joints and flanges are designed for use with the particular type of gasket specified. Substitution of a gasket of different construction or improper dimensions may result in leakage and damage to gasket surfaces. Therefore, any gasket substitutions should be of compatible design.

Any leakage at a gasketed joint should be rectified and not permitted to persist as it may result in damage to the gasket surfaces.


Metal jacketed type gaskets are widely used. When these are used with a tongue and groove joint without a nubbin, the gasket should be installed so that the tongue bears on the seamless side of the gasket jacket. When a nubbin is used, the nubbin should bear on the seamless side.

Spare and Replacement Parts can be ordered directly from API Basco or API Ketema. When ordering parts please provide the name of the part needed, as well as the serial number, type, and size from the nameplate on the unit.

INSTALLATION AND OPERATIONAL PROCEDURES FOR BASCO/WHITLOCK HEAT EXCHANGERS


Special Notes on Type OP Heat Exchangers...

TUBE BUNDLE REMOVED FROM THIS END



BASCO®/WHITLOCK® Exclusive Double "O" Ring Seal Protection

BASCO/WHITLOCK exclusive double "O" ring seal protection permits tube bundle to expand and contract without harmful strain or intermixing of shell and tubeside fluids. "O" rings retain compression, without adjustment, and are unaffected by vibration and temperature changes. No danger of over-tightening. Telltale holes reveal any leakage.



DETAIL OF FLOATING END

To Replace "O" Ring Packing

1. Remove bonnet or channel at floating tubesheet end.
2. Remove existing "O" rings and "O" ring retainer.
3. Clean sealing surfaces including O.D. of floating tubesheet.
4. Assemble inner (shell side) "O" ring.
5. Assemble retainer ring and tighten to shell flange using the bolting that is threaded in the ring.
6. Assemble outer (tube side) "O" ring.
7. Replace floating head bonnet or channel.

Shell Side Test Procedure

1. Remove channel cover at stationary tubesheet end leaving channel bolted to shell.
2. When a bonnet is used at the stationary end in place of a channel, the bonnet can be removed and a test ring substituted to tighten shell and tubesheet gasket.
3. Remove bonnet or channel at floating tubesheet end.
4. The bolting which is threaded into the retainer ring will hold shell side pressure during hydrostatic test.
5. Tube side may be examined with shell pressurized and without draining shell side fluid.

API Heat Transfer

API Heat Transfer Inc.
2777 Walden Avenue
Buffalo, NY 14225
(716) 684-6700

Divisions:

API Airtech ISO-9001 Certified

Air Cooled Aluminum Heat Exchangers

91 North Street • P.O. Box 68
Arcade, New York 14009-0068
(716) 496-5755 • Fax: (716) 496-5776

API Basco ISO-9001 Certified

Basco/Whitlock Shell & Tube Heat Exchangers

2777 Walden Avenue
Buffalo, New York 14225
(716) 684-6700 • Fax: (716) 684-2129

API Ketema

Acme® Refrigeration Equipment

2300 West Marshall Drive
Grand Prairie, Texas 75051
(972) 647-2626 • Fax: (972) 641-1518

API Schmidt-Bretten

Plate Heat Exchangers and

Thermal Process Systems

2777 Walden Avenue
Buffalo, New York 14225
(716) 684-6700 • Fax: (716) 684-2129

API Schmidt-Bretten GmbH.

ISO-9001 Certified

Plate Heat Exchangers and

Thermal Process Systems

P.O. Box 1580 D-75005 Bretten
Pforzheimer Strasse 46
D-75015 Bretten, Germany
7252/53-101 • Fax: 7252/53-201

**Call your local API Sales Representative or
API directly toll-free at 1-877-API HEAT.**

**Visit us at www.apiheattransfer.com or
e-mail us at sales@apiheattransfer.com**


Other Products Available from API Heat Transfer

OptiDesign®



Straight-tube, removable bundle exchangers made from standard components. Floating tube sheet for seal leak detection and easy maintenance. Diameters from 3" (7.62 cm) to 42" (106.68 cm). ASME, API, TEMA, ABS and other codes available.

TEMA Shell and Tube




A wide variety of TEMA types are available using pre-engineered or custom designs in various sizes and materials. Shell diameters from 6" (15.24 cm) to 60" (152.4 cm), ASME, TEMA, API, ABS, TUV, ISPEL and other code constructions available.

Pipeline Aftercoolers



Straight tube, counterflow aftercoolers designed to yield cool, dry compressed air. Available with or without accompanying moisture separators and constructed to a wide variety of design codes. Diameters from 6" (15.24 cm) to 42" (106.68 cm).

Plate Heat Exchangers



Compact units provide excellent heat transfer and small size. Plates are pressed from stainless steel, titanium and other alloys. Gaskets of nitrile, EPDM, Viton®, compressed fiber and Teflon® are used. Gasket-free welded and brazed designs available.

Type 500 Shell and Tube Heat Exchangers




General purpose exchangers designed to cool oil, compressed air and other industrial fluids. A variety of constructions, port configurations and materials are available. ASME and TEMA-C available. Diameters from 3" (7.62 cm) to 12" (30.48 cm).

Brazed Plate Heat Exchangers




Off-the-shelf, standard units reflect the latest in plate heat exchanger technology for maximum performance and low cost. Ideal for OEM or aftermarket applications. Many models stocked and ready to ship. Models for process or refrigeration applications.

Air-Cooled Heat Exchangers



High efficiency, brazed aluminum coolers for cooling a wide variety of liquids and gases with ambient air. Lightweight, yet rugged. Capable of cooling multiple fluids in single unit. Models can be supplied with cooling fan and a variety of drives.

ACME® Packaged Chillers



Packaged chillers with or without pumping systems from 3 to over 400 tons with PLC controls available. Standard and custom designed chiller-barrels and condensers to 2,500 tons with same-day shipment on many units. DX and flooded evaporators available.